

Fire Rating Information:

Tested to **ASTM E 84-05** the Standard Test Method for Surface Burning Characteristics of Building Materials

Material	Flame Spread Index	Smoke Development Index	Classifications
Formica Standard Phenolic	30	110	B
Wilsonart Standard Laminate	50	45	B
Class B Bradmar Solid Plastic Partitions	55	350	B
STD Bradmar Solid Plastic Partitions	98	350	C
Lenox Lockers	98	350	C

* Formica Standard Laminate — Not Fire Rated

Tested to **ASTM E 84-08** the Standard Test Method for Surface Burning Characteristics of Building Materials

Material	Flame Spread Index	Smoke Development Index	Classifications
Baked Enamel Partitions	0	0	A
Stainless Steel Partitions	0	0	A